# **Nationwide House Energy Rating Scheme** NatHERS Certificate No. U2D960N11Y

Generated on 20 Nov 2024 using FirstRate5: 5.3.2b (3.21)

### Property

Address	U6., 56-58 Bream Street,
Lot/DP	2/220244
NCC Class*	Class 2
Туре	New Home

### Plans

Main plan Prepared by

05/11/2024 Attena Group

### Construction and environment

Assessed floor area (m <sup>2</sup> )*						
Conditioned*	88.4					
Unconditioned*	12.4					
Total	100.8					
Garage	N L 4 - 2					

**Exposure type** suburban NatHERS climate zone 56 Mascot AMO

Coogee, NSW, 2034

## ccredited assessor

Name — —	Natascha Harakidas
Business name	AENEC
Email	natascha@aenec.co
Phone	0416316204
Accreditation No.	HERA10140
Assessor Accrediting Orga	anisation
HERA	
Declaration of interest	Declaration complet

om.au

eted: no conflicts



the more energy efficient

# 62.7 MJ/m<sup>2</sup>

R

Predicted annual energy load for heating and cooling based on standard occupancy assumptions.

For more information on your dwelling's rating see: www.nathers.gov.au

Thermal pe	rformance
Heating	Cooling
42.4	20.3
MJ/m²	MJ/m²

### About the rating

NatHERS software models the expected thermal energy loads using information about the design and construction, climate and common patterns of household use. The software does not take into account appliances, apart from the airflow impacts from ceiling fans.

### Verification

To verify this certificate, scan the QR code or visit https://www.fr5.com.au /QRCodeLanding?PublicId= U2D960N11Y When using either link, ensure you are visiting www.FR5.com.au.



### National Construction Code (NCC) requirements

The NCC's requirements for NatHERS-rated houses are detailed in 3.12.0(a)(i) and 3.12.5 of the NCC Volume Two. For apartments the requirements are detailed in J0.2 and J5 to J8 of the NCC Volume One.

In NCC 2019, these requirements include minimum star ratings and separate heating and cooling load limits that need to be met by buildings and apartments through the NatHERS assessment. Requirements additional to the NatHERS assessment that must also be satisfied include, but are not limited to: insulation installation methods, thermal breaks, building sealing, water heating and pumping, and artificial lighting requirements The NCC and NatHERS Heating and Cooling Load Limits (Australian Building Codes Board Standard) are available at www.abcb.gov.au.

State and territory variations and additions to the NCC may also apply.

\* Refer to glossary.

Generated on 20 Nov 2024 using FirstRate5: 5.3.2b (3.21) for 2/220244, U6., 56-58 Bream Street,



## **Certificate Check**

Ensure the dwelling is designed and then built as per the NatHERS Certificate. While you need to check the accuracy of the whole Certificate, the following spot check covers some important items impacting the dwelling's rating.

### Genuine certificate

Does this Certificate match the one available at the web address or QR code in the verification box on the front page? Does the set of NatHERS-stamped plans for the dwelling have a Certificate number on the stamp that matches this Certificate?

### Ceiling penetrations\*

Does the 'number' and 'type' of ceiling penetrations (e.g. downlights, exhaust fans, etc) shown on the stamped plans or installed, match what is shown in this Certificate?

#### Windows

Does the installed window meet the substitution tolerances (SHGC and U-value) and window type, of the window shown on this Certificate? Substituted values must be based on the Australian Fenestration Rating Council (AFRC) protocol.

#### Apartment entrance doors

Does the 'External Door Schedule' show apartment entrance doors? Please note that an "external door" between the modelled dwelling and a shared space, such as an enclosed corridor or foyer, should not be included in the assessment (because it overstates the possible ventilation) and would invalidate the Certificate.

#### Exposure\*

Has the appropriate exposure level (terrain) been applied? For example, it is unlikely that a ground-floor apartment is "exposed" or a top floor high-rise apartment is "protected".

#### Provisional\* values

Have provisional values been used in the assessment and, if so, noted in "additional notes" below?

### **Additional Notes**

Default ceiling penetration density calculated as lighting plan has not been provided. All openable windows are assumed to be fully openable as per NCC 2022 > Volume 2 > 3.9.2.6 (a), (b)(i)(B) as safety devices (STEEL MESH) are in place. North Pointer shown on the plans has been calculated to be the True North. No trees have been modelled as no relevant information has been provided. If these are not in place then this Nathers must be revised.

## Window and glazed door type and performance

Default* windows					
				Substitution to	lerance ranges
Window ID	Window description	Maximum U-value*	SHGC*	SHGC lower limit	SHGC upper limit
ALM-002-01 A	Aluminium B SG Clear	6.7	0.7	0.66	0.74
Custom* windows					
				Substitution to	lerance ranges
Window ID	Window description	Maximum U-value*	SHGC*	SHGC lower limit	SHGC upper limit
No Data Available	e				

### Window and glazed door Schedule

Location	Window ID	Window no.	Height (mm)	Width (mm)	Window type	Opening %	Orientation	Window shading device*
KIT/LIV/DIN/	ALM-002-01 A	W020	2600	5200	sliding	60.0	SSW	No
KIT/LIV/DIN/	ALM-002-01 A	W008	1800	2700	sliding	45.0	WNW	No

\* Refer to glossary.

Generated on 20 Nov 2024 using FirstRate5: 5.3.2b (3.21) for 2/220244, U6., 56-58 Bream Street,

### U2D960N11Y NatHERS Certificate

### 5.2 Star Rating as of 20 Nov 2024

KIT/LIV/DIN/	ALM-002-01 A	W?	2200	840	fixed	0.0	WNW	No
BED1	ALM-002-01 A	W019	2600	2200	sliding	60.0	SSW	No
LAUNDRY/PANTRY	ALM-002-01 A	W010	1800	1575	sliding	45.0	WNW	No
BED2	ALM-002-01 A	W008	1800	2713	sliding	45.0	WNW	No
BED3	ALM-002-01 A	W010	1800	1575	sliding	45.0	WNW	No
BED3	ALM-002-01 A	W012	2600	4000	sliding	60.0	NNE	No
BATH	ALM-002-01 A	W021	1800	1525	sliding	45.0	NNE	No

## Roof window type and performance value

#### Default\* roof windows

				Substitution tolerance ranges		
		Maximum		SHGC lower limit	SHGC upper limit	
Window ID	Window description	U-value*	SHGC*		Si IGC upper innit	
No Data Available						
Custom* roof windows						
				Substitution to	lerance ranges	
		Maximum				
Window ID	) Window description U-value* SHG		SHGC*	SHGC lower limit	SHGC upper limit	
No Data Available						

## Roof window schedule

				Area		Outdoor	Indoor
Location	Window ID	Window no.	Opening %	(m²)	Orientation	shade	shade
No Data Available							

## Skylight type and performance

Skylight ID	Skylight description	
No Data Available		

## Skylight schedule

		Skylight	Skylight shaft	Area Or	rient- Outdoor	r	Skylight shaft
Location	Skylight ID	No.	length (mm)	(m²) ati	tion shade	Diffuser	reflectance
No Data Available							

### External door schedule

Location	Height (mm)	Width (mm)	Opening %	Orientation
HALL	2040	820	100.0	ESE

## External wall type

		Solar	Wall shade		Reflective
Wall ID	Wall type	absorptance	e (colour)	Bulk insulation (R-value)	wall wrap*
1	AENEC - 150AFS+PB insulated	0.2	Light	Glass fibre batt: R1.5 (R1.5)	No
2	AENEC - 150AFS+PB insulated	0.5	Medium	Glass fibre batt: R1.5 (R1.5)	No
3	FR5 - AAC Block	0.2	Light		No
4	FR5 - Internal Plasterboard Stud Wall	0.5	Medium		No

\* Refer to glossary.

Generated on 20 Nov 2024 using FirstRate5: 5.3.2b (3.21) for 2/220244, U6., 56-58 Bream Street,



## External wall schedule

					Horizontal shading	Vertical
	Wall	Height	Width		feature* maximum	shading feature
Location	ID	(mm)	(mm)	Orientation	projection (mm)	(yes/no)
KIT/LIV/DIN/	1	2720	6420	SSW	5117	Yes
KIT/LIV/DIN/	1	2720	1301	NNE	0	No
KIT/LIV/DIN/	1	2720	5643	WNW	554	Yes
BED1	1	2720	537	SSW	0	Yes
BED1	1	2720	2660	SSW	0	Yes
BED1	2	2720	3713	ESE	0	No
BED1	1	2720	1600	NNE	0	No
BED1	2	2720	1334	WNW	0	Yes
ENS	1	2720	1473	NNE	0	No
ENS	2	2720	2841	ESE	0	No
HALL	3	2720	1817	ESE	3963	Yes
HALL	3	2720	2348	ESE	0	Yes
HALL	4	2720	383	NE	0	Yes
LAUNDRY/PANTRY	1	2720	1621	WNW	0	No
BED2	1	2720	3179	WNW	467	Yes
BED3	1	2720	3102	WNW	440	No
BED3	1	2720	4661	NNE	1294	Yes
BATH	1	2720	1604	SSW	0	No
BATH	1	2720	4183	ESE	0	No
BATH	1	2720	1559	NNE	1297	Yes

## Internal wall type

Wall ID Wall type		Area (m <sup>2</sup> ) Bulk insulation
1	FR5 - Internal Plasterboard Stud Wall	86.2

# Floor type

\_

Construction FR5 - 200mm concrete slab	(m²)	Sub-floor ventilation	Added insulation (R-value)	Covering
FR5 - 200mm concrete slab	=		(	Covering
	11.7	Enclosed	R0.0	Timber
FR5 - 200mm concrete slab	23.7	Enclosed	R0.0	Timber
FR5 - 200mm concrete slab	1.4	Enclosed	R0.0	Timber
FR5 - 200mm concrete slab	14.9	Enclosed	R0.0	Timber
FR5 - 200mm concrete slab	1.2	Enclosed	R0.0	Timber
FR5 - 200mm concrete slab	3.3	Enclosed	R0.0	Timber
FR5 - 200mm concrete slab	6.4	Enclosed	R0.0	Timber
FR5 - 200mm concrete slab	4.5	Enclosed	R0.0	Tiles
FR5 - 200mm concrete slab	1.3	Enclosed	R0.0	Tiles
FR5 - 200mm concrete slab	8.9	Enclosed	R0.0	Timber
	FR5 - 200mm concrete slab FR5 - 200mm concrete slab	FR5 - 200mm concrete slab23.7FR5 - 200mm concrete slab1.4FR5 - 200mm concrete slab14.9FR5 - 200mm concrete slab1.2FR5 - 200mm concrete slab3.3FR5 - 200mm concrete slab6.4FR5 - 200mm concrete slab4.5FR5 - 200mm concrete slab1.3	FR5 - 200mm concrete slab23.7EnclosedFR5 - 200mm concrete slab1.4EnclosedFR5 - 200mm concrete slab14.9EnclosedFR5 - 200mm concrete slab1.2EnclosedFR5 - 200mm concrete slab3.3EnclosedFR5 - 200mm concrete slab3.3EnclosedFR5 - 200mm concrete slab6.4EnclosedFR5 - 200mm concrete slab6.4EnclosedFR5 - 200mm concrete slab4.5EnclosedFR5 - 200mm concrete slab1.3Enclosed	FR5 - 200mm concrete slab23.7EnclosedR0.0FR5 - 200mm concrete slab1.4EnclosedR0.0FR5 - 200mm concrete slab14.9EnclosedR0.0FR5 - 200mm concrete slab1.2EnclosedR0.0FR5 - 200mm concrete slab3.3EnclosedR0.0FR5 - 200mm concrete slab6.4EnclosedR0.0FR5 - 200mm concrete slab6.4EnclosedR0.0FR5 - 200mm concrete slab1.3EnclosedR0.0

\* Refer to glossary.

Generated on 20 Nov 2024 using FirstRate5: 5.3.2b (3.21) for 2/220244, U6., 56-58 Bream Street,

### U2D960N11Y NatHERS Certificate

5.2 Star Rating as of 20 Nov 2024

HOUSE	

BED2	FR5 - 200mm concrete slab	2.5	Enclosed	R0.0	Timber
BED3	FR5 - 200mm concrete slab	8.5	Enclosed	R0.0	Timber
BED3	FR5 - 200mm concrete slab	6.1	Enclosed	R0.0	Timber
BATH	FR5 - 200mm concrete slab	5.1	Enclosed	R0.0	Tiles
BATH	FR5 - 200mm concrete slab	1.4	Enclosed	R0.0	Tiles

## Ceiling type

		Bulk insulation R-value (may	Reflective
Location	Construction material/type	include edge batt values)	wrap*
No Data Available			

## Ceiling penetrations\*

Location	Quantity	Туре	Diameter (mm)	Sealed/unsealed
KIT/LIV/DIN/	1	Exhaust Fans	200	Sealed
KIT/LIV/DIN/	14	Downlights	80	Sealed
BED1	7	Downlights	80	Sealed
ENS	2	Downlights	80	Sealed
ENS	1	Exhaust Fans	200	Sealed
HALL	2	Downlights	80	Sealed
LAUNDRY/PANTRY	2	Downlights	80	Sealed
LAUNDRY/PANTRY	1	Exhaust Fans	200	Sealed
BED2	4	Downlights	80	Sealed
BED3	5	Downlights	80	Sealed
BATH	2	Downlights	80	Sealed
BATH	1	Exhaust Fans	200	Sealed

## Ceiling fans

Location	Quantity	Diameter (mm)
BED1	1	1200
BED2	1	1200
BED3	1	1200

## Roof type

Construction	Added insulation (R-value)	Solar absorptance	Roof shade
Slab:Slab - Suspended Slab : 200mm: 200mm Suspended Slab	0.0	0.5	Medium
SlabExt:Slab - Suspended Slab - External Insul : 200mm: 200mm Suspended Slab - External Insul	0.0	0.5	Medium



## **Explanatory Notes**

#### About this report

A NatHERS rating is a comprehensive, dynamic computer modelling evaluation of a home, using the floorplans, elevations and specifications to estimate an energy load. It addresses the building layout, orientation and fabric (i.e. walls, windows, floors, roofs and ceilings), but does not cover the water or energy use of appliances or energy production of solar panels.

Ratings are based on a unique climate zone where the home is located and are generated using standard assumptions, including occupancy patterns and thermostat settings. The actual energy consumption of a home may vary significantly from the predicted energy load, as the assumptions used in the rating will not match actual usage patterns. For example, the number of occupants and personal heating or cooling preferences will vary.

While the figures are an indicative guide to energy use, they can be used as a reliable guide for comparing different dwelling designs and to demonstrate that the design meets the energy efficiency requirements in the National Construction Code. Homes that are energy efficient use less energy, are warmer on cool days, cooler on hot days and cost less to run. The higher the star rating the more thermally efficient the dwelling is.

#### Accredited assessors

To ensure the NatHERS Certificate is of a high quality, always use an accredited or licenced assessor. NatHERS accredited assessors are members of a professional body called an Assessor Accrediting Organisation (AAO).

Australian Capital Territory (ACT) licensed assessors may only produce assessments for regulatory purposes using software for which they have a licence endorsement. Licence endorsements can be confirmed on the ACT licensing register

AAOs have specific quality assurance processes in place, and continuing professional development requirements, to maintain a high and consistent standard of assessments across the country. Non-accredited assessors do not have this level of quality assurance or any ongoing training requirements.

Any questions or concerns about this report should be directed to the assessor in the first instance. If the assessor is unable to address these questions or concerns, the AAO specified on the front of this certificate should be contacted.

#### Disclaimer

The format of the NatHERS Certificate was developed by the NatHERSAdministrator. However the content of each individual certificate is entered and created by the assessor to create a NatHERS Certificate. It is the responsibility of the assessor who prepared this certificate to use NatHERS accredited software correctly and follow the NatHERS Technical Notes to produce a NatHERS Certificate.

The predicted annual energy load in this NatHERS Certificate is an estimate based on an assessment of the building by the assessor. It is not a prediction of actual energy use, but may be used to compare how other buildings are likely to perform when used in a similar way. Information presented in this report relies on a range of standard assumptions (both embedded in NatHERS accredited software and made by the assessor who prepared this report), including assumptions about occupancy, indoor air temperature and local climate.

Not all assumptions that may have been made by the assessor while using the NatHERS accredited software tool are presented in this report and further details or data files may be available from the assessor.

### Glossary

Annual energy load	the predicted amount of energy required for heating and cooling, based on standard occupancy assumptions.
Assessed floor area	the floor area modelled in the software for the purpose of the NatHERS assessment. Note, this may not be consistent with the floor area in the design documents.
Ceiling penetrations	features that require a penetration to the ceiling, including downlights, vents, exhaust fans, rangehoods, chimneys and flues. Excludes fixtures attached to the ceiling with small holes through the ceiling for wiring, e.g. ceiling fans; pendant lights, and heating and cooling ducts.
Conditioned	a zone within a dwelling that is expected to require heating and cooling based on standard occupancy assumptions. In some circumstances it will include garages.
Custom windows	windows listed in NatHERS software that are available on the market in Australia and have a WERS (Window Energy Rating Scheme) rating.
Default windows	windows that are representative of a specific type of window product and whose properties have been derived by statistical methods.
Entrance door	these signify ventilation benefits in the modelling software and must not be modelled as a door when opening to a minimally ventilated corridor in a Class 2 building.
Exposure category - exposed	terrain with no obstructions e.g. flat grazing land, ocean-frontage, desert, exposed high-rise unit (usually above 10 floors).
Exposure category - open	terrain with few obstructions at a similar height e.g. grasslands with few well scattered obstructions below 10m, farmland with scattered sheds, lightly vegetated bush blocks, elevated units (e.g. above 3 floors).
Exposure category - suburban	terrain with numerous, closely spaced obstructions below 10m e.g. suburban housing, heavily vegetated bushland areas.
Exposure category - protected	terrain with numerous, closely spaced obstructions over 10 m e.g. city and industrial areas.
Horizontal shading feature	provides shading to the building in the horizontal plane, e.g. eaves, verandahs, pergolas, carports, or overhangs or balconies from upper levels.

### U2D960N11Y NatHERS Certificate



National Construction Code (NCC) Class	the NCC groups buildings by their function and use, and assigns a classification code. NatHERS software models NCC Class 1, 2 or 4 buildings and attached Class 10a buildings. Definitions can be found at www.abcb.gov.au.
Opening Percentage	the openability percentage or operable (moveable) area of doors or windows that is used in ventilation calculations.
Provisional value	an assumed value that does not represent an actual value. For example, if the wall colour is unspecified in the documentation, a provisional value of 'medium' must be modelled. Acceptable provisional values are outlined in the NatHERS Technical Note and can be found at www.nathers.gov.au
Reflective wrap (also known as foil)	can be applied to walls, roofs and ceilings. When combined with an appropriate airgap and emissivity value, it provides insulative properties.
Roof window	for NatHERS this is typically an operable window (i.e. can be opened), will have a plaster or similar light well if there is an attic space, and generally does not have a diffuser.
Shading device	a device fixed to windows that provides shading e.g. window awnings or screens but excludes eaves.
Shading features	includes neighbouring buildings, fences, and wing walls, but excludes eaves.
Solar heat gain coefficient (SHGC)	the fraction of incident solar radiation admitted through a window, both directly transmitted as well as absorbed and subsequently released inward. SHGC is expressed as a number between 0 and 1. The lower a window's SHGC, the less solar heat it transmits.
Skylight (also known as roof lights)	for NatHERS this is typically a moulded unit with flexible reflective tubing (light well) and a diffuser at ceiling level.
U-value	the rate of heat transfer through a window. The lower the U-value, the better the insulating ability.
Unconditioned	a zone within a dwelling that is assumed to not require heating and cooling based on standard occupancy assumptions.
Vertical shading features	provides shading to the building in the vertical plane and can be parallel or perpendicular to the subject wall/window. Includes privacy screens, other walls in the building (wing walls), fences, other buildings, vegetation (protected or listed heritage trees).